

# Curbs Plus, Inc.

1200 Carline Road  
 Rossville, GA. 30741  
 PH (706) 858-1188 / FAX (706) 866-2339

APPROVED BY: \_\_\_\_\_

DATE APPROVED: \_\_\_\_\_

## (VFPD) (VERTICAL FACE) PLENUM-DIFFUSER SYSTEM

### STANDARD FEATURES

1. G-90 Galvanized Steel Construction.
2. Turning Vanes in Each Quadrant for Maximum Performance. 1.
3. 1" Ultralite Fiber Duct Liner Insulation.
4. Vertical and Horizontal Adjustable Deflection Grilles. 2.
5. Fully Assembled.
6. Standard Duct Connections Provided.
7. Wire Mounting Brackets Provided as Required. 3.
8. Angles For Drop Ceiling Installation Available.
9. Engineered Curb and Duct Packages Available. 4.


### OPTIONS:

PROJECT NAME: \_\_\_\_\_



CITY, STATE: \_\_\_\_\_

CUSTOMER: \_\_\_\_\_

JOB NUMBER: \_\_\_\_\_



PLAN VIEW



ELEVATION

| QUANTITY | MODEL #        | "T" (Sq.) | "B" (Sq.) | "F" | GRILL SIZE | NOMINAL CFM | TAG |
|----------|----------------|-----------|-----------|-----|------------|-------------|-----|
|          | VFPD 1408-5    | 14" Sq.   | 34" Sq.   | 10" | 14" x 8"   | 2,000       |     |
|          | VFPD 1608-6    | 16" Sq.   | 36" Sq.   | 10" | 16" x 8"   | 2,400       |     |
|          | VFPD 2008-7.5  | 20" Sq.   | 40" Sq.   | 10" | 20" x 8"   | 3,000       |     |
|          | VFPD 2010-8.5  | 20" Sq.   | 40" Sq.   | 12" | 20" x 10"  | 3,400       |     |
|          | VFPD 2210-10   | 22" Sq.   | 42" Sq.   | 12" | 22" x 10"  | 4,000       |     |
|          | VFPD 2410-12.5 | 24" Sq.   | 44" Sq.   | 12" | 24" x 10"  | 5,000       |     |
|          | VFPD 2810-15   | 28" Sq.   | 48" Sq.   | 12" | 28" x 10"  | 6,000       |     |
|          | VFPD 3016-20   | 30" Sq.   | 50" Sq.   | 18" | 30" x 16"  | 8,000       |     |
|          | VFPD 3616-25   | 36" Sq.   | 56" Sq.   | 18" | 36" x 16"  | 10,000      |     |
|          | VFPD 3818-30   | 38" Sq.   | 58" Sq.   | 20" | 38" x 18"  | 12,000      |     |
|          | VFPD 4020-40   | 40" Sq.   | 60" Sq.   | 22" | 40" x 20"  | 15,000      |     |